

DISTRICT WATER TESTING LABORATORY, BATHINDA

Water Supply & Sanitation Division no. 3 Complex, Head Water works, Bhagu Road Bathinda
dwtlbathinda@gmail.com

To,

Admin Executive
Delhi Public School , Bathinda


No.: DWTL/BTI/2627/00202 Dated : 31/07/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. DPSBTI/2026-2027/115 Dated: 29/07/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 29/07/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Bathinda

D/A : Test Report



A handwritten signature in black ink, likely of the authorized signatory, is written above the text.

Authorized Signatory
For, District Water Testing Laboratory
Bathinda

DISTRICT WATER TESTING LABORATORY, BATHINDA

Water Supply & Sanitation Division no. 3 Complex, Head Water works, Bhagu Road Bathinda
dwtlbathinda@gmail.com

TEST REPORT

Name & Address of Customer : Admin Executive Delhi Public School , Bathinda		Customer Reference No.	No : DPSBTI/2026-2027/115 Dated : 29/07/2026
		Sample Submitted by	Sh.Gurjinder Singh
		Date of Sample Receipt	29/07/2026
		Analysis Starting Date	29/07/2026
		Analysis completion Date	31/07/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC12834260000161F	Sample Type :	Water
Test Report No.:	DWTL/BTI/2627/00202	Date of Issue :	31/07/2026
Registration no.:	DWTL/BTI/REG2627/00886	Condition of Sample :	Sealed
Collection Point:	NA	Quantity/Type of Bottle:	1000 ml / NA
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Water sample From Delhi Public School , Bathinda / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Bathinda
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.02	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	BDL	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	89	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL(0.5)	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	44	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	76	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	10	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	13	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	18	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%



Reviewed and Approved By

James Jhorar
Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Bathinda

----- End of the Test Report -----